

LOCATION 2014 Baronwood Ct CITY GASTONIA

BETWEEN HEATHWOOD Ct STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	125'	9/14/96		
MAIN TO PROP. LINE	3/4"		60'			
PROP. LINE TO BLDG.	3/4"		65'			

ENTERS: 2014 BRANCHED INTO:

TAP SIZE: 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION EAST side of 2014


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 0 IN. LOCATION South side of Baronwood Ct

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 494647

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY