

LOCATION

508 Beacon St.

CITY

East.

BETWEEN

WALNUT

STREET &amp;

PARK

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3 1/2"	P	76'		11-11	-96
MAIN TO PROP. LINE	"	"	30'			
PROP. LINE TO BLDG.	"	"	46'			

ENTERS:

508

BRANCHED INTO:

TAP SIZE:

3/4"

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

S. of 508

PRESSURE TEST: @

100

psi

For

1 1/4

Hrs.

By

BK

MAIN-SIZE

2

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

96

DEPTH:

3

Ft.

In.

LOCATION

W. of Beacon

"A" P/S READING


P

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	7
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY