

LOCATION 200 Beacon Hills Dr. CITY Boston
 BETWEEN Old Granite Ct STREET & Beady Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>	<u>5-12-99</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>3'</u>			
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>59'</u>			

ENTERS: 200 BRANCHED INTO
 TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W C LOCATION 205' N.W. of center of Old Granite Ct

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.A.
 MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED
 DEPTH 3 FT 0 IN LOCATION 17' SW. of center of Beacon Hills Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 363100

REMARKS:

Test Station		
Reading & location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

