

LOCATION 2566 Ashbourne DR CITY Gastonia
BETWEEN Araglin DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8	P	100'	9-12-01		
MAIN TO PROP LINE	5/8	P	10'			
PROP LINE TO BLDG	5/8	P	90'			

ENTERS Same BRANCHED INTO
TAP SIZE 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION 17' South of


Ashbourne DR + 458' west of Araglin Dr.
PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000

DEPTH 3 FT 6 IN LOCATION 17' South of Ashbourne DR.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR # 0

REMARKS
New Plastic Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P Riser
P/S Pipeline Lead - White Existing Main	E	