

LOCATION 312 Beacon Hills Dr. CITY Gastonia

BETWEEN \_\_\_\_\_ STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	70'	4-27-00		
MAIN TO PROP. LINE	3/4"	P	10'			
PROP. LINE TO BLDG.	3/4"	P	60'			

ENTERS. 312 BRANCHED INTO \_\_\_\_\_

TAP SIZE. 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 184' NW. of center of Beckingham Cr.

PRESSURE TEST @ 100 PSI FOR 4 HRS BY S. H.

MAIN-SIZE 2" C. I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN. LOCATION 20' SW. of center of Beacon Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 300018

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

