

LOCATION 314 Beacon Hills Dr. CITY Carlsbad
BETWEEN Beckingham Ct. STREET & STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|--------------------|-------------|----------|------------|----------------|---------|---------|
| MAIN TO BLDG | <u>3/4"</u> | <u>P</u> | <u>41'</u> | <u>6-13-00</u> | | |
| MAIN TO PROP. LINE | <u>3/4"</u> | <u>P</u> | <u>5'</u> | | | |
| PROP. LINE TO BLDG | <u>3/4"</u> | <u>P</u> | <u>36'</u> | | | |

ENTERS 314 BRANCHED INTO
TAP SIZE: 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION 194' N. of entry of Beckingham Ct.

PRESSURE TEST @ 100 PSI FOR 4 HRS BY SK
PIPE SIZE 3/4" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 2000
DEPTH 2 FT 0 IN LOCATION 70' W. of center of Beacon Hills Dr

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 491700

REMARKS.

|  | Test Station | | |
|---|--|----------|-------|
| | Reading & Location | Lead | Volts |
| | P/S Pipeline Lead - Red New Service | <u>S</u> | |
| | P/S Pipeline Lead - White Existing Main | <u>E</u> | |