

LOCATION - 318 Beacon Hills DR. CITY Gastonia  
BETWEEN Beckingham DR. STREET & STREET

|                   | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|-------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG      | 5/8  | P    | 67'    | 9-20-01   |         |         |
| MAIN TO PROP LINE | 5/8  | P    | 7'     |           |         |         |
| PROP LINE TO BLDG | 5/8  | P    | 60'    |           |         |         |

ENTERS Same

BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 14' west of

Beacon Hills DR & 141' South of Beckingham Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. BALLARD


MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 6 IN LOCATION 14' west of Beacon Hills DR.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR # A0707541

REMARKS

New Plastic Service



| Test Station                               |      |          |
|--|------|----------|
| Reading & Location                         | Lead | Volts    |
| P/S Pipeline Lead - Red<br>New Service     | S    | P. Riser |
| P/S Pipeline Lead - White<br>Existing Main | E    |          |