

LOCATION 320 Beacon Hills Dr. CITY Westerly, R.I.  
BETWEEN Beckingham Ct STREET & Bridgeport Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	96'	9-29-01		
MAIN TO PROP LINE	5/8"	P	12'	"		
PROP LINE TO BLDG	5/8"	P	16'	"		

ENTERS 320 BRANCHED INTO 0

TAP SIZE 1/2" PRESSURE 60 PSI \_\_\_\_\_ INCHES W C LOCATION 224' south


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D. Woody

MAIN-SIZE 2" C I \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3' FT 0" IN LOCATION 31' west of center of cul-de-sac of

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00046433

REMARKS New plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	16.11V
P/S Pipeline Lead - White Existing Main	E	11.1V