

LOCATION 321 Beacon Hills Dr. CITY Castroville

BETWEEN Beckingham Cr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/4"</u>	<u>P</u>	<u>100'</u>	<u>6-18-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>30'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>70'</u>			

ENTERS 321 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 5' W. of center of Beacon Hills Dr.


PRESSURE TEST @ 100 PSI FOR 44 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 38' S. of center of Cul-de-Sac

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L R # A0451072

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	