

LOCATION BEATRICE COSTNER CITY GAST.
BETWEEN MORAN ST. STREET & YORK ST. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>92</u>		<u>8-21-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>84</u>			

ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 93' From @ of MORAN

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.T.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997
DEPTH: 2 FT. 8 IN. LOCATION N. OF Beatrice Costner

"A" P/S READING P. TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY