

LOCATION 2710 Asbourne Dr. CITY Boston

BETWEEN Lismore Dr STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>115'</u>	<u>11-15-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>22'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>93'</u>			

ENTERS 2710 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 281' N. of center of Lismore Dr.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY SLK

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL        PLASTIC ✓ YEAR INSTALLED 1996

DEPTH 3 FT 0 IN LOCATION 36' E. of center of Asbourne Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 337938

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	