

LOCATION 310 Beatrice Costner CITY Gast.  
BETWEEN Grace St. STREET & Moran St. STREET.

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>36'</u>			<u>9-4-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>21'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>3.5'</u>			


ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 74' From @ of Grace St.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D. F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 2 FT. 8 IN. LOCATION S. Beatrice Costner.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY