

LOCATION 2703 Batty Rd Bld. E

CITY Gastonia

BETWEEN McBryde Rd

STREET & Hedgestone Dr

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	37'	1-14-94		
MAIN TO PROP. LINE	3/4	P	(All on Property)			
PROP. LINE TO BLDG.	3/4	P				

ENTERS: 2703

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION Left Side of Bld. E


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Elmore

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1994

DEPTH: 3 Ft. 0 In. LOCATION 236' E Hedgestone Dr

"A" P/S READING ☒ TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY