

LOCATION 2719 Ashbourne Dr. CITY Gastonia
BETWEEN Lismore Ln STREET & Trulee Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	80'	10-28-02		
MAIN TO PROP LINE	5/8"	P	8'	"		
PROP. LINE TO BLDG	5/8"	P	72'	"		

ENTERS: 2719 BRANCHED INTO: 0

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 338' south of

center of Lismore Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D. Woods

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3' FT 0" IN LOCATION 25' west of center of ashbourne Dr.

"A" P/S READING 11.19 TOTAL ANODES 1# 0 17# 0 LR # 323254

REMARKS New Plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>service</u>