

LOCATION 4003 Beaty Rd CITY GAstonia
BETWEEN FAIRGreen DR. STREET & STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>108'</u>	<u>12/30/96</u>		
MAIN TO PROP. LINE	<u>3/4"</u>		<u>33'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>		<u>75'</u>			

ENTERS: 4003 BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION South side of 4003

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT
MAIN-SIZE 6" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1995
DEPTH: 3 FT. 0 IN. LOCATION East side of Beaty Rd

"A" P/S READING 1.40 TOTAL ANODES 1# 0 17# 0 L.R. # 737144

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		