

LOCATION 4124 Beatty Rd CITY BOSTONIA  
BETWEEN Cooks Lake Rd STREET & Toby Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	101'	5/23/95		
MAIN TO PROP. LINE	3/4"		12'			
PROP. LINE TO BLDG.	3/4"		89'			

ENTERS: 4124 BRANCHED INTO:  
TAP SIZE: 3/8" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION North side of 4124


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT

MAIN-SIZE 6" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION East side of Beatty Rd

"A" P/S READING 1.20 TOTAL ANODES 1\* 0 17\* 0 L.R. # 233120

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY