

LOCATION 4531 Beatty RdCITY EastonBETWEEN Union RdSTREET & SR 2673

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>368</u>	<u>6-16-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>48</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>320</u>			

ENTERS: 4539BRANCHED INTO: 4531TAP SIZE: 3/4

PRESSURE

P.S.I.

INCHES W.C.

LOCATION

Wade house

PRESSURE TEST: @

100

psi

For

1/4

Hrs.

By

J. BennettMAIN-SIZE 3/4" Ser

C.I.

BARE STEEL

COATED STEEL

PLASTIC ✓

YEAR INSTALLED

DEPTH:

1 Ft.6 In.

LOCATION

Wade of 4539


"A" P/S READING

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E