

LOCATION 401 Beckingham Ct CITY Easton MA
BETWEEN Beacon Hills STREET & Bridgeport Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>144'</u>	<u>3-13-01</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>40'</u>	<u>"</u>		
PROP. LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>104'</u>	<u>"</u>		

ENTERS 401 Beckingham Ct BRANCHED INTO Ø
TAP SIZE 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION 91' East


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY center of Beacon Hills P.R.

MAIN-SIZE 2" C.I. Ø BARE STEEL Ø COATED STEEL Ø PLASTIC ✓ YEAR INSTALLED 1999

DEPTH. 3' FT 0" IN LOCATION 14' south of center of Beckingham Ct.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø I.R. # 00180993

REMARKS. New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	E	<u>riser</u>