

LOCATION 404 Beckingham CT CITY CANTON

BETWEEN Beacon Hills DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>82'</u>	<u>3-2-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>			
PROP LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>75'</u>			

ENTERS 404 BRANCHED INTO:

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 29' SW. of center of Beckingham CT.


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS BY SEH

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH: 3 FT 0 IN LOCATION 220' SE. of center of Beacon Hills DR.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 I.R. # 106669

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	