

LOCATION 1304 Ashford

CITY Gastonia

BETWEEN VANCE

STREET & S. MILLER

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------|------|--------|-----------|---------|---------|
| MAIN TO BLDG. | 1" | Bare | 4' | | 5-23-94 | |
| MAIN TO PROP. LINE | | | | | | |
| PROP. LINE TO BLDG. | | | | | | |

ENTERS: 1304

BRANCHED INTO: 1306

TAP SIZE: 1" PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION 74' N of Cap Ashford


PRESSURE TEST: @ _____ psi For _____ Hrs. By JP

MAIN - SIZE 1" C.I. _____ BARE STEEL ☒ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1956

DEPTH: 1 Ft. 16 In. LOCATION

"A" P/S READING .60 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: did NOT put 1st ANODE BECAUSE MAIN TO BE RETIRED AT A LATER DATE



| Test Station | | |
|--|-----------|----------------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>SR</u> | <u>Retired</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY