

LOCATION 2020 ASHTON PL

CITY GAST

BETWEEN LESLIE DR

STREET & LINDA ST

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	192		6-6-97	
MAIN TO PROP. LINE	"	"	6			
PROP. LINE TO BLDG.	"	"	186			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4

PRESSURE 60 PSI

INCHES W.C.

LOCATION 20' S From (C) OF ASHTON


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JMV

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION South Side OF ASHTON PL

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E

ENG. DEPT. USE ONLY