

LOCATION 2034 ASHTON PLCITY GASTBETWEEN LESLIESTREET & LINDA

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>134'</u>		<u>6-5-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>6</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>128'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 21' South from (C) OF ASHTONPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JmMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION SOUTH SIDE OF ASHTON PL"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY