

LOCATION 2040 ASHTON PLCITY GASTBETWEEN LINDA STSTREET & LESLIE DR

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>4</u>		<u>TIE</u>	<u>OVER</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>				

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 18' S. from (C) OF ASHTONPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY gnMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 3 FT. 0 IN. LOCATION _____A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY