

LOCATION 1100 ATCHLEY AVE CITY GASTONIA
BETWEEN HART ST STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>74'</u>	<u>9-22-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>3'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>71'</u>			

ENTERS 1100 BRANCHED INTO 0

TAP SIZE 1/2 PRESSURE 60 PSI INCHES W C LOCATION 89' W of LOT
HART ST


PRESSURE TEST @ 100 PSI FOR 4 HRS BY ER

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1998

DEPTH 3 FT 0 IN LOCATION 13' N of C of ATCHLEY AVE

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 00875815

REMARKS.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Riser</u>