

LOCATION 714 Belfast CITY Castonville

BETWEEN Northway STREET & Brightington STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>D</u>	<u>12'</u>	<u>Replaced</u>	<u>2-18-97</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 720 BRANCHED INTO: 714 + 706

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 105 PSI FOR 44 HRS. BY EP

MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1976


DEPTH: 3 FT. 6 IN. LOCATION _____

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS:

Test point CW River at # 720 Belfast.

Tracer wire bonded to ext gas pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>River Plaza</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY