


LOCATION 3730 Bellevue DrCITY GastoniaBETWEEN FairlaneSTREET & Pinecrest

STREET

| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|-----------|-------------|-----------------|---------|---------|
| MAIN TO BLDG. | <u>314</u> | <u>P</u> | <u>145.</u> | <u>10-17-95</u> | | |
| MAIN TO PROP. LINE | <u>11</u> | <u>11</u> | <u>15</u> | | | |
| PROP. LINE TO BLDG. | <u>11</u> | <u>11</u> | <u>130</u> | | | |

ENTERS: 3730BRANCHED INTO: 0TAP SIZE: 5/8PRESSURE 60 P.S.I. _____ INCHES W.C.LOCATION E of Cof
FairlanePRESSURE TEST: @ 100 psi For 1/4 Hrs. By BCMAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1961DEPTH: 3 Ft. _____ In. LOCATION 11' S of Cof Bellevue"A" P/S READING 2.0 TOTAL ANODES 1* - 17* - L.R. # 518125

REMARKS:



| Test Station | | |
|--|-----------|----------|
| Reading & Location | Lead | Volts |
| P/S Pipeline Lead - Red New Service | <u>SR</u> | <u>P</u> |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | |

ENG. DEPT. USE ONLY