

LOCATION 1509 Belmar Dr. CITY Camden
BETWEEN Lyn Haven STREET & JVA STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>7-23-54</u>	<u>Tied over 101' of</u>	
MAIN TO PROP. LINE					<u>Ext 3/4" Galv to</u>	
PROP. LINE TO BLDG.					<u>Ext 4" Plastic main</u>	

ENTERS: 1509 Belmar BRANCHED INTO: 1615 Linwood Rd
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP


MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

Tie in wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>Riser</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY