

LOCATION 1550 Belmar Dr.

CITY GASTONIA

BETWEEN Kenworthy Dr.

STREET & LYNN HAVEN

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	0'	7-23-94	Tied over	9-23-88
MAIN TO PROP. LINE					95' Existing	
PROP. LINE TO BLDG.					3/4 PLASTIC	

ENTERS: 1550

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 114' E of C of Belmar Dr.


PRESSURE TEST: @ 100 psi For 14 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 19' N of C of Kenworthy Dr.

"A" P/S READING PLASTIC TOTAL ANODES 1* 17* L.R. #

REMARKS: Bare Main Replacement Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser PLASTIC
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY