


LOCATION 1812 Belmar Dr.CITY GastoniaBETWEEN Old west Ln.STREET & Kemberly

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>12'</u>	<u>7-30-94</u>	<u>trail over 87' 3/4 P. Serv.</u>	
MAIN TO PROP. LINE					<u>to Ext 1" P. main</u>	
PROP. LINE TO BLDG.						

ENTERS: 1812BRANCHED INTO: —TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 20' W. of C of
Belmar Dr.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By GPMAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 Ft. 0 In. LOCATION"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY