

LOCATION 104 N Belvedere Ave. CITY GASTONIA
BETWEEN DAVIS Ave. STREET & Craig St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>87'</u>			<u>5-20-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>33'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>54'</u>			


ENTERS: SAMP BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 222' From CM of
DAVIS Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHJ
MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION Westside of Belvedere Ave.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY