

LOCATION 100 S Belvedere Ave. CITY Gastonia

BETWEEN Davis Ave. STREET & Franklin Blvd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>82'</u>		<u>5-</u>	<u>19-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>31'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>51'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 30' from @ of

Davis Ave.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.H./

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION West side of Belvedere Ave.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:

Test Station			ENG. DEPT. USE ONLY
Reading & Location	Lead	Volts	
P/S Pipeline Lead - Red New Service	S		
P/S Pipeline Lead - White Existing Main	E		

