

LOCATION 101 S Belvedere Ave. CITY Castonia

BETWEEN DAVIS STREET & Franklin Blvd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>39'</u>		<u>5-</u>	<u>19-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>23'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>16'</u>			

ENTERS: SAME BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 86' From @ of


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY DLH

MAIN-SIZE 4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION North side of Davis Ave.

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY