

LOCATION 1203 S. BELVEDERE.

CITY GASTONIA

BETWEEN Edgemont

STREET & Franklin

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	C&W	42'	4-1-80		9-14-94
MAIN TO PROP. LINE				TIED OVER TO NEW MAIN		
PROP. LINE TO BLDG.						

ENTERS: 1203

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Moore 9-14-94

MAIN-SIZE 2 C.I. — BARE STEEL — COATED STEEL — PLASTIC X YEAR INSTALLED 1993

DEPTH: 3 Ft. — In. LOCATION

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. #

REMARKS: Existing Insulator Removed



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	105
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY