

LOCATION 1606 Berry St. CITY Ge. ASTORIA  
BETWEEN PEAR St. STREET & END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>120'</u>	<u>1-20-96</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>"</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>"</u>	<u>80'</u>			

ENTERS: 1606 BRANCHED INTO: —  
TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 14' S. of cap  
Berry St.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>PR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY