

LOCATION 1613 E. Berry St CITY GASTONIA  
BETWEEN Pear St STREET & \_\_\_\_\_ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	Plastic	43'	12/29/95		
MAIN TO PROP. LINE	3/4"		10'			
PROP. LINE TO BLDG.	3/4"		33'			

ENTERS: 1613 BRANCHED INTO: \_\_\_\_\_  
TAP SIZE: 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION West side of 1613


PRESSURE TEST: @ 100 psi For 14 Hrs. By DTA

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1995

DEPTH: 3 Ft. 0 In. LOCATION South side of Berry St

"A" P/S READING 0 TOTAL ANODES 1\*0 17\*0 L.R. # 652859

REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY