

LOCATION 5209 Berryview LN CITY SANTANA
 BETWEEN Summerell Ave STREET & End of Culderack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>120'</u>	<u>12-8-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>45'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>75'</u>			

ENTERS 5209 BRANCHED INTO 0
 TAP SIZE 1/2 PRESSURE 60 PSI INCHES WC LOCATION

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION

A P/S READING Plastic N/O TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	<u>Riser</u>
P/S Pipeline Lead White Existing Main	E	<u>PLASTIC</u>

