

LOCATION 2851 Berwick Ln. CITY GASTONIA

BETWEEN Lockshire Ln. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	90'	10-24-95		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	85'			

ENTERS: 2851 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 245' S. of center of

Lockshire Ln.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Hufford

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991

DEPTH: 3 Ft. 0 In. LOCATION 20' W. of center of Berwick Ln.

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 543705

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY