

LOCATION 2912 Berwick Ln. CITY Easton
BETWEEN DEVONSHIRE CT. STREET & CANOPY CT. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	5/8"	P	96'	11.17.01		
MAIN TO PROP LINE	"	"	5			
PROP LINE TO BLDG	1"	"	91			

ENTERS 2912 BRANCHED INTO _____
TAP SIZE 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION E side of 2912


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY TJM

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH _____ FT _____ IN _____ LOCATION S. side of BERWICK LANE

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	