

LOCATION 2970 Berwick LrCITY CassloniaBETWEEN CanabySTREET & Dead end

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$\frac{3}{4}$	P	124'	12-7-98		
MAIN TO PROP. LINE	1"	"	15'			
PROP. LINE TO BLDG.	1"	b	109			

ENTERS: 2970

BRANCHED INTO:

TAP SIZE: 1/2

PRESSURE \_\_\_\_\_ PSI

\_\_\_\_\_ INCHES W.C.

LOCATION 27' N. of CoffBerwickPRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JPMAIN-SIZE 2

C.I. \_\_\_\_\_

BARE STEEL \_\_\_\_\_

COATED STEEL \_\_\_\_\_

PLASTIC ✓YEAR INSTALLED 1991DEPTH: 2 FT. 6 IN.


LOCATION \_\_\_\_\_

"A" P/S READING P

TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_

L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY