

LOCATION 2104 Bethlehem AVE. CITY Gastonia
BETWEEN Separk Cir. STREET & N. Newhope Rd. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____


MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1958

DEPTH: 3' FT. 6" IN. LOCATION Bethlehem AVE

"A" P/S READING 1.846 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bonded insulated 3/4" C.W. 1/2 service tee to 2" C.W. main. C.P. # 01872.

Readings: .406 before bond to 1.800 after bond was made.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY