

LOCATION 2106 Bethlehem AveCITY GastoniaBETWEEN Se Park Cir.

STREET &

N. New Hope Rd

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>C/w</u>				
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS:

BRANCHED INTO:

TAP SIZE:

PRESSURE

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @

PSI

FOR

HRS.

BY

MAIN-SIZE 2"

C.I.

BARE STEEL

COATED STEEL ☒

PLASTIC

YEAR INSTALLED 1958DEPTH: 3 FT. 6 IN.


LOCATION

Bethlehem Ave"A" P/S READING 1.800

TOTAL ANODES 1#

17#

L.R. #

REMARKS: Bonded insulated 3/4 C/w service to 2" C/w main C.P. #01872RReading: .700 before and 1.800 After bond was made.

Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY