

LOCATION 409 N. BEVERLY DRCITY GASTONIABETWEEN McCORMICKSTREET & PEARL

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>20'</u>		<u>6-19-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>17'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: <u>3/4"</u>	PRESSURE <u>60</u> PSI	INCHES W C	LOCATION <u>N. SIDE OF 409</u>
-----------------------	------------------------	------------	--------------------------------


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BT.

MAIN-SIZE <u>2"</u>	C.I. _____	BARE STEEL _____	COATED STEEL _____	PLASTIC <u>✓</u>	YEAR INSTALLED <u>97</u>
---------------------	------------	------------------	--------------------	------------------	--------------------------

DEPTH: 3 FT IN LOCATION SOUTH SIDE OF PEARL

"A" P/S READING <u>N/A</u>	TOTAL ANODES 1# _____ 17# _____	L.R. # _____
----------------------------	---------------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY