

LOCATION 502 N. BEVERLY DRCITY GASTONIABETWEEN PEARLSTREET & DUHART

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>93'</u>		<u>10-19-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>40'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>53'</u>			

ENTERS:

BRANCHED INTO:

TAP SIZE: 3/4"PRESSURE 60 PSI

INCHES W.C.

LOCATION W. SIDE OF 502PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BTMAIN-SIZE 2"

C.I. _____

BARE STEEL _____


COATED STEEL _____

PLASTIC ☒YEAR INSTALLED 97DEPTH: 3 FT. 6 INLOCATION WEST SIDE OF BEVERLY"A" P/S READING N/A

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY