

LOCATION 504 & 506 N. BEVERLY DR CITY GASTONIA

BETWEEN PEARL STREET & DUHART STREET

	SIZE	TYPE	504 LENGTH	506	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>96'</u>			<u>6-19-97</u>	
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>40'</u>				
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>56'</u>				

ENTERS: 504 N. BEVERLY DR. BRANCHED INTO: 506 N. BEVERLY DR.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION N. SIDE OF 504


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY B.T.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97

DEPTH: 3 FT 6 IN LOCATION WEST SIDE OF BEVERLY

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY