

LOCATION 506 N. Beverly Dr.CITY GastoniaBETWEEN McCormickSTREET & Pearl

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>96</u>		<u>103' of 1" BARE</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30</u>		<u>1-3-96</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>66</u>			

ENTERS: 506BRANCHED INTO: 0

TAP SIZE: <u>3/8</u>	PRESSURE <u>20</u> P.S.I. _____ INCHES W.C.	LOCATION
----------------------	---	----------


PRESSURE TEST: @ 100 psi For 144 Hrs. By EP

MAIN-SIZE <u>2"</u>	C.I. _____ BARE STEEL <input checked="" type="checkbox"/> COATED STEEL _____ PLASTIC _____	YEAR INSTALLED <u>1955</u>
---------------------	--	----------------------------

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING <u>.6</u>	TOTAL ANODES 1* _____ 17* <u>1</u>	L.R. # _____
---------------------------	------------------------------------	--------------

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Pl 103/4</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY