

LOCATION 513 & 511 N. BEVERLY CITY GASTONIA
BETWEEN PEARL STREET & DUHART STREET


	SIZE	TYPE	513 LENGTH	511	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>PLASTIC</u>	<u>106'</u>	<u>16'</u>		<u>6-23-97</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>5'</u>				
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>101'</u>				

ENTERS: 513 N. BEVERLY DR BRANCHED INTO: 511 N. BEVERLY DR.
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION S. SIDE OF 513

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY B.T.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 97
DEPTH: 3 FT. 6 IN. LOCATION WEST SIDE OF BEVERLY

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY