

LOCATION 304 Biggers st. CITY East.
BETWEEN YORK st. STREET & Dead end STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>30'</u>		<u>10-</u>	<u>22-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>28'</u>			

ENTERS: SAME BRANCHED INTO: 306 Biggers st.
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 120' from @ of York st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997
DEPTH: 3 FT. 8 IN LOCATION S. OF Biggers st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY