

LOCATION 313 Biggers st. CITY Gast.  
BETWEEN Dead end STREET & YORK st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>30'</u>		<u>10-</u>	<u>24-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>4'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>26'</u>			


ENTERS: SAME BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 125' From Dead end

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY D.F.  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT 8 IN LOCATION S. OF Biggers st.

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY