

LOCATION 2702 Birchfield Dr CITY Gastonia  
BETWEEN Hill Ln STREET & Midway STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	55	9-18-96		
MAIN TO PROP. LINE	1	"	5			
PROP. LINE TO BLDG.	1	"	50			

ENTERS: 2702 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 100 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 85' S of c of Hill

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By BC  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1968  
DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION 9'E of c of Birchfield

"A" P/S READING \_\_\_\_\_ TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # 501408

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY