

LOCATION 3022 Birch Field Lane

CITY Easton, VA

BETWEEN HUFFMAN Rd.

STREET &amp; Midway

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	60'	9-1-95	Tied on to	Existing 3/4
MAIN TO PROP. LINE					Of w Stub. Used. Exist	
PROP. LINE TO BLDG.					Service which was Temp. Retired.	

ENTERS: 3026 HUFFMAN BRANCHED INTO: 3022 Birch Field Lane.

TAP SIZE: PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 292' N of C of Huffman Rd.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN SIZE 3/4 C.I. BARE STEEL COATED STEEL ☒ PLASTIC ☐ YEAR INSTALLED \_\_\_\_\_

DEPTH: 2 Ft. 0 In. LOCATION 139' E of C of Birch Field Dr.

"A" P/S READING .04 TOTAL ANODES 1\* 1 17\* L.R. #

REMARKS: Service Not on CP System.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY